

SERVICE BULLETIN




SF – 080

DATE: November 29, 2018
TO: All Service and Parts Managers
SUBJECT: Honeywell to White Rodgers Gas Valve Wiring Adaptor

Since June 2015 (1506 serial prefix), Goodman has been using Honeywell gas valves on Two-Stage 80% and 90% furnaces. Starting in July 2018 (1807 serial prefix), Goodman began transitioning to White Rodgers gas valves on these products.

In order to use the White Rodgers valve to replace a factory installed Honeywell valve, you will need to order an adaptor harness when ordering your gas valve.

If you are replacing the Honeywell gas valve (**part # 0151M00028**) with the White Rodgers gas valve (**part# 0151M00027s**), you will need the wiring adaptor harness (**part# 0259M00005**).



These parts are available through the Service Parts department. Please contact your customer service representative to order.

T: 888-593-9988 | F: 713-316-5541

Produced by Goodman Business Unit Technical Services | 19001 Kermier Road | Waller, TX 77484

All rights reserved. Goodman products are subject to continuous improvements. Goodman reserves the right to modify information in the bulletin without notice and without incurring any obligations. Amana® is a registered trademark of Maytag Corporation or its related companies and is used under license to Goodman Company, L.P., Houston, TX.